

iH²O INSULATED PIPE



CHILLED WATER iH2O PRE-INSULATED PIPING (R>2.2)

SERVICE PIPE/CASING: STAINLESS STEEL/SPIRAL EBONY

SPECIFICATION: SCHEDULE 10S

Service Pipe Material:

Stainless Steel (k = 13 W/m^oK)

Insulation Material:

DPE1783R PUR (k = 0.024 W/m^oK)

Casing Material:

Painted Steel (k = 50 W/m^oK)

Pipe Diameter/ OD (mm)	Equivalent Imperial (in)	Class		NB (mm)	Casing (Ebony--Spiral Wound) --- Outer Diameter (mm)																						Dry & Wet mass of iH2O insulated pipe* (standard stock items)			
					152		178		203		229		254		305		330		400		450		508		610				711	
		Schedule	Thickness (mm)		PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	PUR_Thk (mm)	R-Val (m²K/W)	Dry Mass of insulated pipe (kg/m)	Wet Mass of insulated pipe (kg/m)
60.3	2"	10s	2.77	54.8	45.9	2.90	58.9	3.98																			6.8	9.2		
73.0	2 1/2"	10s	3.05	66.9	39.5	2.30	52.5	3.28	65.0	4.29																	8.8	12.3		
88.9	3"	10s	3.05	82.8			44.6	2.55	57.1	3.46	70.1	4.48															10.6	16.0		
114.3	4"	10s	3.05	108.2					44.4	2.41	57.4	3.29	69.9	4.19													13.2	22.3		
141.3	5"	10s	3.40	134.5							43.9	2.28	56.4	3.08	81.9	4.85											16.9	31.2		
168.3	6"	10s	3.40	161.5									42.9	2.16	68.4	3.75	80.9	4.59									20.7	41.2		
219.1	8"	10s	3.76	211.6											43.0	2.08	55.5	2.79	90.5	4.97							27.2	62.3		
273.1	10"	10s	4.19	264.7															63.5	3.15	88.5	4.64					37.1	92.1		
323.9	12"	10s	4.57	314.8															38.1	1.74	63.1	3.06	92.1	4.72			46.6	124.4		
355.6	14"	10s	4.78	346.0																	47.2	2.19	76.2	3.74			54.2	148.2		
406.4	16"	10s	4.78	396.8																			50.8	2.34	101.8	5.12	58.7	182.4		
457	18"	10s	4.78	447.4																					76.5	3.64	69.0	226.2		
508.0	20"	10s	5.54	496.9																					51.0	2.31	101.5	4.94	82.7	276.6
559.0	22"	10s	5.54	547.9																						76.0	3.53	94.2	330.0	
610.0	24"	10s	6.35	597.3																						50.5	2.25	111.2	391.4	

BLUE BLOCKS DENOTE STANDARD STOCK ITEMS

*Dry mass of insulated pipe = Service pipe mass + PUR insulation mass + Casing mass,

Wet mass of insulated pipe = Dry mass of insulated pipe + Service fluid (water) mass